

	Organization/Unit:	إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title:	TEST REPORT FORMALDEHYDE LEVELS FROM WOOD PRODUCTS USING DESICCATOR	عنوان الوثيقة:	
	Doc. Ref. :	DM-DCLD-F-IBL-0100	رقم الوثيقة:	

INFRASTRUCTURE AND BUILDING MATERIALS LABORATORIES SECTION

Report No:	888152	Request No:	EMTX-2025-0010203
Project No:	BP-2025-114	Report Date:	10/03/2025 10:30AM
Project Name:	TESTING SERVICE FOR ALAMCO TIMBERMARK TRADING L.L.C		
Consultant:	NO SPECIFIC CONSULTANT		
Contractor:	ALAMCO TIMBERMARK TRADING L.L.C		
Location: *	WAREHOUSE		
Source: *	NOT GIVEN		
Sample Description: *	WOOD		
Product Name: *	SIBERIAN LARCH-(LARIX SIBIRICA)		
Sampling Date/Time: *	11/02/2025 10:00AM	Lot/Batch/Coil/Heat No. *	-
Receiving Date/Time:	13/02/2025 07:13AM	Lot Size: *	-
Sample Size /Quantity:	36 pieces	Sender No:	SIBERIAN LARCH-(LARIX SIBIRICA)
Material/Mix Type: *	SIBERIAN LARCH-(LARIX SIBIRICA)	Laying Date/Production Date: *	NA
Nominal Size / Working Block Size (mm) : **			

TEST RESULTS

PARAMETER	RESULTS		
Formaldehyde Concentration (Average per unit volume)-micro g/ml	<0.30		
ROOM TEMPERATURE Deg.C	23		
RELATIVE HUMIDITY (AVERAGE)	54		
VALUE OF BLANK	0		
DILUTION FACTOR	1		
SPECTROPHOTOMETER USED	SHIMADZU UV-1601		
SPECIFICATION LIMIT *	NG		
Sampled By:	CLIENT REPRESENTATIVE / AMIRKHON	Tested By:	RAMAKM
Sampled Brought By:	CLIENT REPRESENTATIVE / AMIRKHON	Testing Date:	13/02/2025 07:13AM
Sampling Method:	NOT GIVEN	Sampling Report No:	NA
Test Method:	ASTM D5582-22	Test Method Variation:	NIL
Remarks:	CUSTOMER PERFORMED SAMPLING AND PROVIDED THE SAMPLE; THE RESULTS APPLY ONLY TO THE SAMPLE AS RECEIVED AND TESTED.THIS TEST METHOD IS CHOSEN BY CUSTOMER.		

Disclaimer : * Information is supplied by the customer and Laboratory is not responsible for this data.

	Organization/Unit:	إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title:	TEST REPORT FORMALDEHYDE LEVELS FROM WOOD PRODUCTS USING DESICCATOR	عنوان الوثيقة:	
	Doc. Ref. :	DM-DCLD-F-IBL-0100	رقم الوثيقة:	

INFRASTRUCTURE AND BUILDING MATERIALS LABORATORIES SECTION

Report No:	888152	Request No: EMTX-2025-0010203
------------	--------	-------------------------------

To verify this document please go to : <https://www.dm.gov.ae/#check-tab5>
 Enter Document ID: **EMTX-2025-0010203** and Verification Code: **1537138**
 or Scan the QR code below.



***** END OF REPORT *****

This report is computer approved and authorized by In Charge of Lab and does not require any signature.

Date of Issue :	26/04/2024	Rev No. : 5
Shared - Confidential / مشترك - خاص	Level of Confidentiality / درجة السرية	Page 2 of 2