

	Organization/Unit:	إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title:	TEST REPORT MOISTURE CONTENT - WOOD	عنوان الوثيقة:	
	Doc. Ref. :	DM-DCLD-F-IBL-0100	رقم الوثيقة:	

INFRASTRUCTURE AND BUILDING MATERIALS LABORATORIES SECTION

Report No:	877483	Request No:	EMTX-2025-0010203
Project No:	BP-2025-114	Report Date:	18/02/2025 03:07PM
Project Name:	TESTING SERVICE FOR ALAMCO TIMBERMARK TRADING L.L.C		
Consultant:	NO SPECIFIC CONSULTANT		
Contractor:	ALAMCO TIMBERMARK TRADING L.L.C		
Location: *	WAREHOUSE		
Source: *	NOT GIVEN		
Sample Description: *	WOOD		
Product Name: *	SIBERIAN LARCH-(LARIX SIBIRICA)		
Sampling Date/Time: *	11/02/2025 10:00AM	Lot/Batch/Coil/Heat No.*	-
Receiving Date/Time:	13/02/2025 08:39AM	Lot Size: *	-
Sample Size /Quantity:	36 pieces	Sender No:	SIBERIAN LARCH-(LARIX SIBIRICA)
Material/Mix Type: *	SIBERIAN LARCH-(LARIX SIBIRICA)	Laying Date/Production Date: *	NA
Nominal Size / Working Block Size (mm) : **			

TEST RESULTS

PARAMETER	RESULTS			
DATE OF SPECIMEN RECEIVED	11/02/2025			
SIZE OF SPECIMEN (mm)	50x50x40			
TEST TEMPERATURE deg C	103+/-2			
SPECIMEN NO.	1	2	3	4
MOISTURE CONTENT (% BY WT)	11.4	11.6	10.9	10.3
AVG. MOISTURE CONTENT (% BY WT)	11.1			
Sampled By:	CLIENT REPRESENTATIVE / AMIRKHON		Tested By:	NASARDAR
Sampled Brought By:	CLIENT REPRESENTATIVE / AMIRKHON		Testing Date:	13/02/2025 08:39AM
Sampling Method:	NOT GIVEN		Sampling Report No:	NA
Test Method:	BS EN 322 : 1993		Test Method Variation:	NIL
Remarks:	NIL			

Disclaimer : * Information is supplied by the customer and Laboratory is not responsible for this data.

To verify this document please go to : <https://www.dm.gov.ae/#check-tab5>
Enter Document ID: **EMTX-2025-0010203** and Verification Code: **1537140**
or Scan the QR code below.



	Organization/Unit:	إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title:	TEST REPORT MOISTURE CONTENT - WOOD	عنوان الوثيقة:	
	Doc. Ref. :	DM-DCLD-F-IBL-0100	رقم الوثيقة:	

INFRASTRUCTURE AND BUILDING MATERIALS LABORATORIES SECTION

Report No:	877483	Request No: EMTX-2025-0010203
------------	--------	-------------------------------

***** END OF REPORT *****

This report is computer approved and authorized by In Charge of Lab and does not require any signature.



LB-TEST-014

PO Box 67, Dubai, UAE - Tel: (+971 4) 3027216 - Email: labs@dm.gov.ae - Website: <http://www.dm.gov.ae>

This report shall not be reproduced except in full without approval of the laboratory.

Date of Issue :	26/04/2024	Rev No. : 5
Shared - Confidential / مشترك - خاص	Level of Confidentiality / درجة السرية	Page 2 of 2